
CUT OFF TOP LANTERN: DARK SKY COMPLIANT, PENDANT MOUNTED HORIZONTAL LED


DISTRIBUTION, TEMPERED GLOBE

ASSEMBLY TYPE III OR V

# BOSTON COMMON LED SERIES BC-19-LEX-LED-S7

<u>IP 66 RATED</u> LED CHAMBER





<u>EXAMPLE</u>

BC-19-LEX-LED-5000-75-120/277-III-BLK

BC-19-LEX-LED-	-		-		
Series	Kelvin	Wattage	Voltage	Distribution	Color
LIGHT				AT FINIOLI	

STANDARD	WATTAGE RANGE	VOLTAGE	LIGHT	COLOR OF POWDER COAT FINISH	
KELVIN	ACTUAL = EQUIVALENT	RANGE-AC	DISTRIBUTION		
3000 4000 5000	□ 60w=100w HPS/150w MH EQ. − 7,400 Lmns □ 80w=150w HPS/250w MH EQ. − 9,800 Lmns □ 115w=200w HPS/320w MH EQ. −12,800 Lmns □ 140w=250w HPS/400w MH EQ. −15,800 Lmns □ 240w=400w HPS/750w MH EQ. −28,300 Lmns	120/277v	TYPE III	☐ (BLK) BLACK ☐ (HG) HAND BRUSHED GREEN ☐ (BRZ) BRONZE ☐ (HR) HAND BRISHED GRAY ☐ (GRN) GREEN ☐ CUSTOM	

## LUMINAIRE SPECIFICATION

#### HOUSING

The pendant mount luminaire shall be core cast aluminum. Aluminum shall be certified as pure #356 alloy, free of any porosity, foreign materials or cosmetic fillers. Castings shall be uniform wall thickness with no warping or mold shifting. Minimum wall thickness shall be 3/16°. Electrical components are one piece plug-in. LED assembly unit shall be mounted with four stainless steel screws. The core ports for vetilation located just beneath pendant housing and LED unit mounting ring increase thermal management and over all LED longity. A optional refractor globe shall be molded of acrylic with external refractors designed for a Type III or V light distribution pattern.

#### LED POWER SUPPLY

All electrical components and materials shall be UL-recognized and wired by a certified UL technician. The electrical assembly is prewired with quick disconnects for servicing. Electrical components rated for 1 amp but only draws 300 milliamps which adds to the units longevity. Input voltage120–277v with 36kV surge suppression. All components are IP66 rated with a 1.0 PF rating. Service life up to 100,000 hours life at -40°C to +40°C Ambient, Operating Temperature. <20% Total Harmonic Distortion

#### LED CIRCUIT BOARD

LED's are available in 3000, 4000 & 5000 Kelvin with a Type III or Type V light distribution, Instant On/Off soft start. PF rating of 95% Solid State panel.

#### MOUNTING

Fixture shall be mounted to the arm by the Self Leveling Plumberizer. Plumberizer shall mount to arm with S.S. set screws and thru-bolt.

Catalog Name: <u>BC-19-LEX-LED-S7</u>	Date: <u>03.22.19</u>
Revision History:N/A	Revision #: <u>0</u>
Niland Approval: Luis M.Gomez Customer Approval:	Page: <u>5</u> of <u>5</u>

#### CERTIFICATION

The fixture shall be UL Certified for wet location use. LED unit is DLC Listed with IP66 Components. Designed to UL 1598 & UL 1449 3rd Edition. UL Driver is installed. Complies with IEEE C62.41 and FCC Part 15 Class A.

#### FINISH-AAMA-2604-5

Fixture finish shall consist of degreasing, phosphate acid etching with 140°+ deionized water, rinsed, oven dry off and top coated with a thermoset TGIC super polyester powder coat finish designed not to chalk or fade for many years. All Niland Company powders must pass a minimum 3000-hour salt spray test for corosion resistance.

#### <u>WARRANTY</u>

Quick 60+ month warranty on LED module and electronic driver. Please contact manufacturer for more details.

### PHOTOMETRICS

Complete photometric data for all fixtures is available in IES-formatted. A certified independent laboratory performs all testing. Call the Niland Company directly for more information.





QUICK 60+ Warranty On Parts

NILAND COMPANY PH: (915) 779-1405 FAX: (915) 779-3618 E-MAIL: INFO@NILANDCO.COM
320 N. Clark El Paso, Tx 79905 PH: 800-648-9013 FAX: 888-779-3065 BEPAGE: HTTP://www.nilandco.com